

# Stormwater Treatment Structures (BMPs) Standard Operating Procedures



**Town of Tewksbury, MA**  
Department of Public Works  
999 Whipple Road  
Tewksbury, MA 01876

Updated June 30, 2020

# Table of Contents

## Stormwater Treatment Structures (BMPs) – Town of Tewksbury, MA

**Introduction..... 1**

**Inspection Procedures & Maintenance Schedules..... 1**

- Bioretention Areas and Rain Gardens.....1
- Constructed Stormwater Wetlands .....2
- Extended Dry Detention Basins .....3
- Proprietary Media Filters .....3
- Sand and Organic Filters .....4
- Wet Basins .....5
- Dry Wells .....5
- Infiltration Basins .....6

### List of Appendices

Appendix A. Field Inspection/Data Collection Forms

## Introduction

Best Management Practices (BMPs) are policies, procedures and structures designed to reduce stormwater pollution, prevent contaminant discharges to natural water bodies, and reduce stormwater facility maintenance costs. Constructed BMPs are permanent site features designed to treat stormwater before infiltrating it to the subsurface or discharging it to a surface water body.

This Standard Operating Procedure provides a general summary of inspection procedures for eight common constructed BMPs, including:

1. Bioretention Areas and Rain Gardens
2. Constructed Stormwater Wetlands
3. Extended Dry Detention Basins
4. Proprietary Media Filters
5. Sand and Organic Filters
6. Wet Basins
7. Dry Wells
8. Infiltration Basins

## Inspection Procedures & Maintenance Schedules

This SOP is based on the Massachusetts Stormwater Handbook and is not intended to replace that document. This SOP is also not intended to replace the Stormwater BMP Operation and Maintenance (O&M) Plan required by the Massachusetts Wetlands Protection Act, Order of Conditions. The following are inspection and

### Bioretention Areas and Rain Gardens

Bioretention areas and rain gardens are shallow depressions filled with sandy soil, topped with a thick layer of mulch and planted with dense native vegetation. There are two types of bioretention cells:

- Filtering bioretention area: Areas that are designed solely as an organic filter; and
- Exfiltration bioretention area: Areas that are configured to recharge groundwater in addition to acting as a filter.

### Inspection & Maintenance

Regular inspection and maintenance are important to prevent against premature failure of bioretention areas or rain gardens. Regular inspection and maintenance of pretreatment devices and bioretention cells for sediment buildup, structural damage and standing water can extend the life of the soil media.

**Maintenance Schedule: Bioretention Areas and Rain Gardens**

<b>Activity</b>	<b>Time of Year</b>	<b>Frequency</b>
Inspect for soil erosion and repair	Year round	Monthly
Inspect for invasive species and remove if present	Year round	Monthly
Remove trash	Year round	Monthly
Mulch Void Areas	Spring	Annually
Remove dead vegetation	Fall and Spring	Bi-Annually
Replace dead vegetation	Spring	Annually
Prune	Spring or Fall	Annually
Replace all media and vegetation	Late Spring/Early Summer	As Needed

When failure is discovered, excavate the bioretention area, scarify the bottom and sides, replace the filter fabric and soil, replant vegetation and mulch the surface.

Never store snow within a bioretention area or rain garden. This would prevent required water quality treatment and the recharge of groundwater.

**Constructed Stormwater Wetlands**

Constructed stormwater wetlands maximize the pollutant removal from stormwater through the use of wetland vegetation uptake, retention and settling. Constructed storm water wetlands must be used in conjunction with other BMPs, such as sediment forebays.

**Inspection & Maintenance**

Regular inspection and maintenance are important to prevent against premature failure of bioretention areas or rain gardens. Regular inspection and maintenance of pretreatment devices and bioretention cells for sediment buildup, structural damage and standing water can extend the life of the soil media.

**Maintenance Schedule, Constructed Stormwater Wetlands: Years 0-3**

<b>Activity</b>	<b>Time of Year</b>	<b>Frequency</b>
Inspect for invasive species and remove if present	Year round	Monthly
Record and Map:	Year round	Annually
Types and distribution of dominant wetland plants	Year round	Bi-Annually
Presence and distribution of planted wetland species	Spring	Annually
Presence and distribution of invasive species	Fall and Spring	Bi-Annually
Indications other species are replacing planted wetland species	Spring	Annually
Percent of standing water that is not vegetated	Spring or Fall	Annually
Replace all media and vegetation	Late Spring/Early Summer	As Needed
Stability of original depth zones and micro-topographic features		
Accumulation of sediment in the forebay and micropool and survival rate of plants		

**Maintenance Schedule, Constructed Stormwater Wetlands: Years 4-Lifetime**

<b>Activity</b>	<b>Time of Year</b>	<b>Frequency</b>
Inspect for invasive species and remove if present	Year round	Monthly
Clean forebays	Year round	Annually
Clean sediment in basin/wetland system	Year round	Once every 10 years
Mulch Void Areas	Spring	Annually
Remove dead vegetation	Fall and Spring	Bi-Annually
Replace dead vegetation	Spring	Annually
Prune	Spring or Fall	Annually
Replace all media and vegetation	Late Spring/Early Summer	As Needed

When failure is discovered, excavate the bioretention area, scarify the bottom and sides, replace the filter fabric and soil, replant vegetation and mulch the surface.

Never store snow within a constructed stormwater wetland. This would prevent required water quality treatment and the recharge of groundwater.

**Extended Dry Detention Basins**

Extended dry detention basins are designed to control both stormwater quantity and quality. These BMPs are designed to hold stormwater for at least 24 hours, allowing solids to settle and to reduce local and downstream flooding. Pretreatment is required to reduce the potential for overflow clogging. The outflow may be designed as either fixed or adjustable. Additional nutrient removal may be achieved by a micropool or shallow marsh.

**Inspection & Maintenance**

Annual inspection of extended dry detention basins is required to ensure that the basins are operating properly. Potential problems include: erosion within the basin and banks, tree growth on the embankment, damage to the emergency spillway and sediment accumulation around the outlet. Should any of these problems be encountered, necessary repairs should be made immediately.

**Maintenance Schedule: Extended Dry Detention Basins**

<b>Activity</b>	<b>Time of Year</b>	<b>Frequency</b>
Inspect basins	Spring and Fall	Bi-Annually, and during and after major storms
Examine outlet structure for clogging or high outflow release velocities	Spring and Fall	Bi-Annually
Mow upper stage, side slopes, embankment and emergency spillway	Spring through Fall	Bi-Annually
Remove trash and debris	Spring	Bi-Annually
Remove sediment from basin	Year round	At least once every 5 years

**Proprietary Media Filters**

Media Filters are designed to reduce total suspended solids and other target pollutants, such as organics, heavy metals or nutrients, which are sorbed onto the filter media, which is contained in a concrete structure. The substrate used as filter media depends on the target pollutants, and may consist of leaf compost, pleated fabric, activated charcoal, perlite, amended sand in combination with perlite, and zeolite. Two types of Media Filters are manufactured: Dry Media Filters, which are designed to dewater within 72 hours; and Wet Media Filters, which maintain a permanent pool of water as part of the treatment system.

**Inspection & Maintenance**

Maintenance in accordance with the manufacturer’s requirements is necessary to ensure stormwater treatment. Inspection or maintenance of the concrete structure may require OSHA confined space training. Dry Media Filters are required to dewater in 72 hours, thus preventing mosquito and other insect breeding. Proper maintenance is essential to prevent clogging. Wet Media Filters require tight fitting seals to keep mosquitoes and other insects from entering and breeding in the permanent pools. Required maintenance includes routine inspection and treatment.

**Maintenance Schedule: Proprietary Media Filters**

<b>Activity</b>	<b>Time of Year</b>	<b>Frequency</b>
Inspect for standing water, trash, sediment and clogging	Per manufacturer’s schedule	Bi-Annually (minimum)
Remove trash and debris	N/A	Each Inspection
Examine to determine if system drains in 72 hours	Spring, after large storm	Annually
Inspect filtering media for clogging	Per manufacturer’s schedule	Per manufacturer’s schedule

**Sand and Organic Filters**

Sand and organic filters, also known as filtration basins, are intended for quality control rather than quantity control. These filters improve water quality by removing pollutants through a filtering media and settling pollutants on top of the sand bed and/or in a pretreatment basin. Pretreatment is required to prevent filter media from clogging. Runoff from the filters is typically discharged to another BMP for additional treatment.

**Inspection & Maintenance**

If properly maintained, sand and organic filters have a long design life. Maintenance requirements include raking the sand and removing sediment, trash and debris from the surface of the BMP. Over time, fine sediments will penetrate deep into the sand requiring replacement of several inches or the entire sand layer. Discolored sand is an indicator of the presence of fine sediments, suggesting that replacement of the sand should be completed.

**Maintenance Schedule: Proprietary Media Filters**

<b>Activity</b>	<b>Frequency</b>
Inspect filters and remove debris	After every major storm for the first 3 months after construction completion. Every 6 months thereafter.

Wet Basins

Wet basins are intended to treat stormwater quality through the removal of sediments and soluble pollutants. A permanent pool of water allows sediments to settle and removes the soluble pollutants, including some metals and nutrients. Additional dry storage is required to control peak discharges during large storm events, and if properly designed and maintained wet basins can add fire protection, wildlife habitat and aesthetic values to a property.

Inspection & Maintenance

To ensure proper operation, wet basin outfalls should be inspected for evidence of clogging or excessive outfall releases. Potential problems to investigate include erosion within the basin and banks, damage to the emergency spillway, tree growth on the embankment, sediment accumulation around the outlet and the emergence of invasive species. Should any of these problems be encountered, perform repairs immediately. An on-site sediment disposal area will reduce sediment removal costs.

**Maintenance Schedule: Wet Basins**

<b>Activity</b>	<b>Time of Year</b>	<b>Frequency</b>
Inspect wet basins	Spring and/or Fall	Annually (Minimum)
Mow upper stage, side slopes, embankment and emergency spillway	Spring through Fall	Bi-Annually (Minimum)
Remove sediment, trash and debris	Spring through Fall	Bi-Annually (Minimum)
Remove sediment from basin	Year round	As required, but at least once every 10 years

Dry Wells

Dry wells are used to infiltrate uncontaminated runoff. These BMPs should never be used to infiltrate stormwater or runoff that has the potential to be contaminated with sediment and other pollutants. Dry wells provide groundwater recharge and can reduce the size and cost required of downstream BMPs or storm drains. However, they are only applicable in drainage areas of less than one acre and may experience high failure rates due to clogging.

Inspection & Maintenance

Proper dry well function depends on regular inspection. Clogging has the potential to cause high failure rates. The water depth in the observation well should be measured at 24 and 48 hour intervals after a storm and the clearance rate calculated. The clearance rate is calculated by dividing the drop in water level (inches) by the time elapsed (hours).

**Maintenance Schedule: Dry Wells**

<b>Activity</b>	<b>Frequency</b>
Inspect dry wells	After every major storm for the first 3 months after construction completion. Annually thereafter.

## Infiltration Basins

Infiltration basins are designed to contain stormwater quantity and provide groundwater recharge. Pollution prevention and pretreatment are required to ensure that contaminated stormwater is not infiltrated. Infiltration basins reduce local flooding and preserve the natural water balance of the site, however high failure rates often occur due to improper siting, inadequate pretreatment, poor design and lack of maintenance.

### Inspection & Maintenance

Regular maintenance is required to prevent clogging, which results in infiltration basin failure. Clogging may be due to upland sediment erosion, excessive soil compaction or low spots. Inspections should include signs of differential settlement, cracking, erosion, leakage in the embankments, tree growth on the embankments, riprap condition, sediment accumulation and turf health.

#### Maintenance Schedule: Infiltration Basins

<b>Activity</b>	<b>Time of Year</b>	<b>Frequency</b>
Preventative maintenance	Spring and Fall	Bi-Annually
Inspection	Spring and Fall	After every major storm for the first 3 months after construction completion. Bi-annually thereafter and discharges through the high outlet orifice.
Mow/rake buffer area, side slopes and basin bottom	Spring and Fall	Bi-Annually
Remove trash, debris and organic matter	Spring and Fall	Bi-Annually

## **Appendix A: Field Inspection/Data Collection Forms**

---

## INSPECTION OF BIORETENTION AREAS / RAIN GARDENS

### General Information

BMP Description	Bioretention Area / Rain Garden		
BMP Location			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			

### Specific Information

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Inspect for soil erosion and repair	Monthly	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Inspect for invasive species and remove if present	Monthly	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove trash	Monthly	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Mulch void areas	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove dead vegetation	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Replace dead vegetation	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Prune	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Replace all media and vegetation	As Needed	Yes <input type="checkbox"/> No <input type="checkbox"/>	

**INSPECTION OF CONSTRUCTED STORMWATER WETLANDS  
Years 0-3 of Operation**

**General Information**

BMP Description	Constructed Stormwater Wetland		
BMP Location			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			

**Specific Information**

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Inspect for invasive species and remove if present	Monthly	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Replace all media and vegetation	As Needed	Yes <input type="checkbox"/> No <input type="checkbox"/>	

In addition, the following information should be recorded and mapped at least once per year:

- Types and distribution of dominant wetland plants
- Presence and distribution of planted wetland species
- Presence and distribution of invasive species
- Indications other species are replacing planted wetland species
- Percent of standing water that is not vegetated
- Replace all media and vegetation
- Stability of original depth zones and micro-topographic features
- Accumulation of sediment in the forebay and micropool and survival rate of plants

**INSPECTION OF CONSTRUCTED STORMWATER WETLANDS  
Year 4 - Lifetime of Operation**

**General Information**

BMP Description	Constructed Stormwater Wetland		
BMP Location			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			

**Specific Information**

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Inspect for invasive species and remove if present	Monthly	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Clean forebays	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Clean sediment in basin/wetland system	Once every 10 years	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Mulch void areas	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove dead vegetation	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Replace dead vegetation	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Prune	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Replace all media and vegetation	As Needed	Yes <input type="checkbox"/> No <input type="checkbox"/>	

## INSPECTION OF EXTENDED DRY DETENTION BASINS

**Inspections should be conducted bi-annually, and during and after major storm events.**

### General Information

BMP Description	Extended Dry Detention Basin		
BMP Location			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			

### Specific Information

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Examine outlet structure for clogging or high outflow release velocities	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Mow upper stage, side slopes, embankment and emergency spillway	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove trash and debris	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove sediment from basin	At least once every 5 years	Yes <input type="checkbox"/> No <input type="checkbox"/>	

## INSPECTION OF PROPRIETARY MEDIA FILTERS

### General Information

BMP Description	Media Filter		
BMP Location			
Media Type			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			

### Specific Information

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Inspect for standing water, trash, sediment and clogging	Bi-Annually (minimum)	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove trash and debris	Each Inspection	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Examine to determine if system drains in 72 hours	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Inspect filtering media for clogging	Per manufacturer's schedule	Yes <input type="checkbox"/> No <input type="checkbox"/>	

## INSPECTION OF SAND AND ORGANIC FILTERS

**Inspections should be conducted after every major storm event for the first 3 months following completion, then every 6 months thereafter.**

### General Information

BMP Description	Sand/Organic Filter		
BMP Location			
Media Type			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			

### Specific Information

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Remove sediment, trash, and debris	Every 6 months	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Rake sand	Every 6 months	Yes <input type="checkbox"/> No <input type="checkbox"/>	

## INSPECTION OF DRY WELLS

**Regular inspections should be conducted after every major storm event for the first 3 months following completion, then annually thereafter.**

### General Information

BMP Description	Dry Well		
BMP Location			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			
Describe condition of dry well at time of inspection			

After a major storm event, the water depth in the observation well should be measured at 24 and 48 hour intervals and the clearance rate calculated.

## INSPECTION OF WET BASINS

**Inspections should be conducted after every major storm event for the first 3 months following completion, then biannually thereafter.**

### General Information

BMP Description	Wet Basin		
BMP Location			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			
Describe condition of wet basin at time of inspection			

### Specific Information

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Preventative maintenance	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Mow/rake buffer area, side slopes and basin bottom	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove trash, debris and organic matter	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Inspect and clean pretreatment devices	Every other month and after every major storm event	Yes <input type="checkbox"/> No <input type="checkbox"/>	

## INSPECTION OF OTHER BMP (Custom Inspection Form for Detention Basins)

### General Information

BMP Description	<b>Town Owned Stormwater Detention Basin</b>		
BMP Location			
Inspector's Name			
Date of Inspection		Date of Last Inspection	
Start Time		End Time	
Type of Inspection: Regular <input type="checkbox"/> Pre-Storm Event <input type="checkbox"/> During Storm Event <input type="checkbox"/> Post-Storm Event <input type="checkbox"/>			
Describe the weather conditions at time of inspection			

### Specific Information

Maintenance Activity	Maintenance Frequency	Is Status of BMP Satisfactory?	Corrective Action Needed
Mow bottom, upper stage, side slopes, embankment and emergency spillways	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove Sediment Build Up on Bottom of Detention Area	At least once every 5 years	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Restoration of Rip-Rap at Inlet(s)	As Needed	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Clear Inlet/Outlet(s)	Bi-Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove Small Trees and Brush in Detention Area	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove Larger Trees in Detention Area	At least once every 5 years	Yes <input type="checkbox"/> No <input type="checkbox"/>	
Remove of Trash, debris, or illicit discharge	Annually	Yes <input type="checkbox"/> No <input type="checkbox"/>	

Notes:

---



---



---

